

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 1964-

DATE. 08-09-2026

It is certify that an inspection team headed by E.E. P.H Division, Dhamdaha (Purnea)

(Name of Officers with designation) from Kumar Nikhil (Executive Engineer)

(Name of Department Office) inspected the Vidya Vihar Residential School, Vill- Parora, Block-K.Nagar, District- Purnea on 08-09-2026 and found that the Vidya Vihar Residential School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygenic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 08-09-2026 to 08.02.2027

Signature with Seal:

Name: Kumar Nikhil

Designation: Executive Engineer

Name & Address of the Office:

EXECUTIVE ENGINEER
PUBLIC HEALTH DIVISION
DHAMDAHA

To

Vidya Vihar Residential School,
Vill- Parora, Block-K.Nagar,
District- Purnea

The filled up certificate should be either in Hindi or English, if it is issued in Vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name: Purnea

Month: September 2026

Sl. No.	Block	Panchyat	Village/ Habitation	Location Details	Parameters												
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	SO ₄	NO ₃	Total Coli
1	K. Nagar	Kajha Ganeshpur	Parora	Vidya Vihar Residential School (Raw Water)	7.2	3	372	190	102	12	7.3	12	90	12	27	BDL	NEGATIVE
1	K. Nagar	Kajha Ganeshpur	Parora	Vidya Vihar Residential School (Treated Water)	7.0	2	295	85	60	12	7.3	7	40	0.3	22	BDL	NEGATIVE
Desirable Limit*					6.5-8.5	5.0	-	500	200	75	30	250	200	1.0	200	45	NEGATIVE
Permissible Limit* in absence of alternate source					NR	10.0	-	2000	600	200	100	1000	600	N.R	400	NR	NEGATIVE

P. H. Divison, Dhamdaha

Chemist

Executive Engineer

P. H. Division Dhamdaha